



Regarding:

EILEEN BRADLEY
WRIGHTSTOWN TOWNSHIP
2203 2ND STREET PIKE
WRIGHTSTOWN, PA 18940

EILEEN BRADLEY
WRIGHTSTOWN TOWNSHIP
2203 2ND STREET PIKE
WRIGHTSTOWN, PA 18940

Account No: W03259, WRIGHTSTOWN TOWNSHIP
Project No: W03259, WRIGHTSTOWN TOWNSHIP

P.O. No:
PWSID No:

Inv. No: 1033970

Sample Number L2813750-1
Sample Description DRINKING WATER - SMITH FARM - KITCHEN SINK
Samp. Date/Time/Temp 12/19/08 01:00pm NA F
Sampled by Customer Sampled
Received Temp 38 F Iced (Y/N): Y

Parameter	Method	Result	RLs	Test Date, Time, Analyst
COLIFORM-MF	SM 9222B	4 col/100ml	1. col/100ml	12/19/08 02:45PM AMD
E. COLI CONFIRM	SM 9221E+MUG	NEG col/100ml	1. col/100ml	12/20/08 01:00PM AMD
STANDARD PLATE COUNT	SM 9215B	76 col/ml	1. col/ml	12/19/08 02:45PM AMD

**** NOTES CONCERNING THE ABOVE SAMPLE ****

A water supply is considered bacteriologically "SAFE" if no Coliform bacteria are detected. To be considered "SAFE" your report should indicate "<1 col/100ml" or "NEG" for the Coliform Test. If your report indicates a positive result "POS" or a value of one (1) or greater then your supply is "UNSAFE FOR DRINKING" contact your local Health Dept. or QC for advice.

- A result of "ND" indicates the concentration of the analyte tested was either not detected or below the RLs.
 - All analysis, except field tests are conducted in Southampton, PA unless otherwise identified.
 - The test "pH lab" is analyzed upon receipt in the laboratory, the result will not be suitable for regulatory purposes.
 - Actual times of analysis for parameters reported <24 hrs are available upon request. All testing is completed within the required holding time unless otherwise noted.
 - Definitions: ND=not detected; NEG=negative; POS=positive; COL=colonies; RLs=Laboratory reporting limits; L/A=laboratory accident; TNTC=too numerous to count.
 - A result marked with "DRY" indicates that the result was calculated and reported on a dry weight basis.
 - QC NELAP ID's: PA 09-00131, NJ PA166, FL E87954, NY 11223, CT PH-0768, DE PA-018, KY 90228, MD 206, EPA PA00018, Bioassay: PA 09-03574, NJ PA034, FL E87953, KS E10373, SC 89020001.
 - QC STATE ID's: Wind Gap, NJ PA001, PA 48-01334; E RUTHERFORD NJ02015; Vineland NJ06005; Reading PA 06-03543.
 - All samples are collected as "grab" samples unless otherwise identified.
 - MCL= is the EPA recommended "maximum contaminant level" for a parameter, PLs=customer specific permit limits.
- Regulatory authorities are assessing substantial fines for testing omissions. Please track your sample collections and results on a weekly, monthly, or quarterly basis to ensure compliance. QC's internet program 'LIVE ACCESS' will provide you with real-time access to collection dates and results. Please contact Customer Service for further information on acquiring LIVE ACCESS.

Thomas J. Hines
Thomas J. Hines, President